



2/17/2019

**Work Order: 19B0753**  
**Project: Code Copper**

**Sandy City Corporation**

**Attn:** [REDACTED]

**9150 South 150 East**

**Sandy, UT 84070**

**Client Service Contact: 801.262.7299**

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director



## Certificate of Analysis

**Lab Sample No.: 19B0753-01**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:04 PM
<b>Sample Site:</b> Q1 1940 E 10980 S	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0068	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0005	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-02**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:50 PM
<b>Sample Site:</b> Q2 2087 E Pleasant Valley Ct	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.121	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0026	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-03**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 4:45 PM
<b>Sample Site:</b> R1K 11121 S Tall Pines Wy	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0123	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-04**

<p><b>Name:</b> Sandy City Corporation</p> <p><b>Sample Site:</b> R2K 11083 S Tall Pines Wy</p> <p><b>Comments:</b></p> <p><b>Sample Matrix:</b> Drinking Water</p> <p><b>PO Number:</b></p> <p><b>Source Code:</b></p>	<p><b>Sample Date:</b> 2/16/2019 5:05 PM</p> <p><b>Receipt Date:</b> 2/16/2019 7:44 PM</p> <p><b>Sampler:</b> Sandy City Workers</p> <p><b>Project:</b> Code Copper</p> <p><b>System No.:</b> UTAH18028</p> <p><b>Sample Point:</b></p> <p><b>Report to State:</b></p>
---	--

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0119	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-05**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:10 PM
<b>Sample Site:</b> R3K 11103 S Tall Pines Wy	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0250	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-06**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:15 PM
<b>Sample Site:</b> R4K 11067 S Tall Pines Wy	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0636	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0016	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-07**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:46 PM
<b>Sample Site:</b> R5K 1973 E Aspen View Cr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0677	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-08**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:00 PM
<b>Sample Site:</b> R6K 1998 E Aspen View Cr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0422	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0015	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-09**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:14 PM
<b>Sample Site:</b> S1 11116 S Wyngate	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0298	1.3	0.0010	mg/L	EPA 200.8	02/16/2019	02/17/2019	
Lead, Total	0.0013	0.015	0.0005	mg/L	EPA 200.8	02/16/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-10**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:27 PM
<b>Sample Site:</b> S2 11132 S Wyngate	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0523	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0015	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-11**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:26 PM
<b>Sample Site:</b> S3 11144 S Wyngate	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0551	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-12**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:43 PM
<b>Sample Site:</b> S4 2016 Justin Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0076	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-13**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:46 PM
<b>Sample Site:</b> S5 2015 Justin Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0061	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-14**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:52 PM
<b>Sample Site:</b> S6 2029 Justin Park Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0995	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0021	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-15**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 5:56 PM
<b>Sample Site:</b> S7 2001 E Justin Park Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0196	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0006	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-16**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 3:30 PM
<b>Sample Site:</b> T1 1953 E Ryan Park Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.409	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0052	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-17**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:14 PM
<b>Sample Site:</b> T2K 1898 Ryan Park Ave	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.384	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0020	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-18**

<p><b>Name:</b> Sandy City Corporation</p> <p><b>Sample Site:</b> T3K 1908 Ryan Park Ave</p> <p><b>Comments:</b></p> <p><b>Sample Matrix:</b> Drinking Water</p> <p><b>PO Number:</b></p> <p><b>Source Code:</b></p>	<p><b>Sample Date:</b> 2/16/2019 6:21 PM</p> <p><b>Receipt Date:</b> 2/16/2019 7:44 PM</p> <p><b>Sampler:</b> Sandy City Workers</p> <p><b>Project:</b> Code Copper</p> <p><b>System No.:</b> UTAH18028</p> <p><b>Sample Point:</b></p> <p><b>Report to State:</b></p>
--	--

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.726	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0015	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-19**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:36 PM
<b>Sample Site:</b> T4K 11036 Ryan Park	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.562	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0008	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-20**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:39 PM
<b>Sample Site:</b> T5K 11048 Ryan Park	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.119	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0012	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-21**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:18 PM
<b>Sample Site:</b> U 11156 S Foxmoor Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0638	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0008	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-22**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:30 PM
<b>Sample Site:</b> U 11080 S Fooxmoor Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.162	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



# Certificate of Analysis

**Lab Sample No.: 19B0753-23**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:35 PM
<b>Sample Site:</b> U 11066 S Foxmoor Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.415	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0086	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-24**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:40 PM
<b>Sample Site:</b> U 11052 S Foxmoor Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.218	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-25**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:54 PM
<b>Sample Site:</b> U 11026 S Foxmoor Dr	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.0764	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

**Lab Sample No.: 19B0753-26**

<b>Name:</b> Sandy City Corporation	<b>Sample Date:</b> 2/16/2019 6:59 PM
<b>Sample Site:</b> U 1867 E Ryan Park Ave	<b>Receipt Date:</b> 2/16/2019 7:44 PM
<b>Comments:</b>	<b>Sampler:</b> Sandy City Workers
<b>Sample Matrix:</b> Drinking Water	<b>Project:</b> Code Copper
<b>PO Number:</b>	<b>System No.:</b> UTAH18028
<b>Source Code:</b>	<b>Sample Point:</b>
	<b>Report to State:</b>

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
<b>Metals</b>								
Copper, Total	0.105	1.3	0.0010	mg/L	EPA 200.8	02/17/2019	02/17/2019	
Lead, Total	0.0008	0.015	0.0005	mg/L	EPA 200.8	02/17/2019	02/17/2019	



## Certificate of Analysis

### Report Footnotes

#### Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

#### Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

**BLANK** values in the MCL column indicate no standard.









**DRINKING WATER SAMPLES ONLY**

**CHEMTECH - FORD ANALYTICAL LABORATORY**

**CHAIN OF CUSTODY**

COMPANY: Sandy City Corporatoin  
 ADDRESS: 9150 South 150 East  
 CITY/STATE/ZIP: Sandy, Utah 84070  
 PHONE #: \_\_\_\_\_ FAX: \_\_\_\_\_  
 CONTACT: \_\_\_\_\_ PROJECT: Code Copper  
 EMAIL: \_\_\_\_\_

BILLING ADDRESS: \_\_\_\_\_  
 BILLING CITY/STATE/ZIP: \_\_\_\_\_  
 PURCHASE ORDER: \_\_\_\_\_



**TURNAROUND TIME REQUIRED\*:** \_\_\_\_\_  
 \* Expedited turnaround subject to additional charge

State System Number

Send to State  
 Yes  No

Please fill in all blue highlighted areas. Thank you!

TESTS REQUESTED										Bacteria			LAB FAIL Ref #
Lead	Copper	Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)	HPC (Plate Count)	R = Routine	I = Investigative	TR = Trigger Source	RP = Repeat	REPEAT				
					OR = Original Location	UP = Upstream	DN = Downstream						
X													
X													
X													
X													
X													
X													
X													
X													
X													

Lab Use Only	CLIENT SAMPLE INFORMATION					
	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine
30763	1. 11156 S Fox Moor Dr.	2/16/19	6:18p			
21	2.					
22	3.					
23	4.					
24	5.					
25	6. 11080 S. Foxmoor Dr.	2/16/19	6:30p			
26	7. 11064 S. Foxmoor Dr.	2/16/19	6:35p			
27	8. 11052 S. Foxmoor Dr.	2/16/19	6:40p			
28	9.					
29	10. 11024 S. Foxmoor Dr.	2/16/19	6:54p			

Sampled by: [print] \_\_\_\_\_ Sampled by: [signature] \_\_\_\_\_  
 Special Instructions: \_\_\_\_\_  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:30p Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:36PM  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:35PM Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:36PM  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:45PM Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 1945

ON ICE ~~NOT ON ICE~~ Temp (C°): 12.4  
 Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.

CHEMTECH-FORD  
 9632 South 500 West  
 Sandy, UT 84070

801.262.7299 PHONE  
 866.792.0093 FAX  
[www.ChemtechFord.com](http://www.ChemtechFord.com)

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).  
 Client agrees to pay collection costs and attorney's fees.

**DRINKING WATER SAMPLES ONLY**

**CHEMTECH - FORD ANALYTICAL LABORATORY**

**CHAIN OF CUSTODY**

COMPANY: Sandy City Corporatoin  
 ADDRESS: 9150 South 150 East  
 CITY/STATE/ZIP: Sandy, Utah 84070  
 PHONE #: \_\_\_\_\_ FAX: \_\_\_\_\_  
 CONTACT: \_\_\_\_\_ PROJECT: Code Copper  
 EMAIL: \_\_\_\_\_

BILLING ADDRESS: \_\_\_\_\_  
 BILLING CITY/STATE/ZIP: \_\_\_\_\_  
 PURCHASE ORDER: \_\_\_\_\_



**TURNAROUND TIME REQUIRED\*:** \_\_\_\_\_

\* Expedited turnaround subject to additional charge

State System Number

Send to State

Yes  No

Please fill in all blue highlighted areas. Thank you!

TESTS REQUESTED	Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)	HPC (Plate Count)	Bacteria	
				R = Routine	I = Investigative
				TR = Trigger Source	RP = Repeat
				<b>REPEAT</b>	
				OR = Original Location	UP = Upstream
				DN = Downstream	

Lab Use Only	CLIENT SAMPLE INFORMATION					
	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine
B0753	1. 1867 E. Ryan Park Ave.	2/16/19	7:30P			
26 2/16/19	2.					
	3.					
	4.					
	5.					
	6.					
	7.					
	8.					
	9.					
	10.					

Sampled by: [print] \_\_\_\_\_ Signature: \_\_\_\_\_  
 Special Instructions: \_\_\_\_\_  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:30P  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:35PM  
 Relinquished by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:45 PM

ON ICE ~~NOT ON ICE~~ Temp (C°): 12.4  
 Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.  
 Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:30PM  
 Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 7:36 PM  
 Received by: [signature] \_\_\_\_\_ Date/Time: 2/16/19 1945

CHEMTECH-FORD  
 9632 South 500 West  
 Sandy, UT 84070

801.262.7299 PHONE  
 866.792.0093 FAX  
[www.ChemtechFord.com](http://www.ChemtechFord.com)

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).  
 Client agrees to pay collection costs and attorney's fees.

