

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

Annual Water Quality Report for the period of January 1 to December 31, 2014

Name : Stacey Nicholson or Jeremy Kinkade

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Phone : 903-886-3458

NORTH HUNT SUD is Purchased Surface Water

For more information regarding this report contact:  
Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (\_\_\_\_) \_\_\_\_-\_\_\_\_.

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

**Information about Source Water Assessments**

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:  
<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 - PS 1 / CR 4903 CR 4903	GW	Active	441 CR 3930 Wolfe City, Texas 75496
2 - PS 2 / 7841 FM 68W 7841 FM 68W	GW	Active	7841 FM 68 Wolfe City, Texas 75496
SW FROM CITY OF COMMERCE CC FROM TX1160003	SW	Active	CR 4511 Commerce, Texas 75428
SW FROM CITY OF COMMERCE CC FROM TX1160003	SW	Active	CR 4513 Commerce, Texas 75428

**This page intentionally left blank**

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

**2014 Regulated Contaminants Detected**

**Lead and Copper**

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
<b>Copper</b>	08/01/2013	1.3	1.3	0.0999	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
<b>Lead</b>	08/01/2013	0	15	1.63	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Water Quality Test Results**

Definitions:

The following tables contain scientific terms and measures, some of which may require explanation.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL:

million fibers per liter (a measure of asbestos)

na:

not applicable.

NTU:

nephelometric turbidity units (a measure of turbidity)

pCi/L:

picocuries per liter (a measure of radioactivity)

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

**Water Quality Test Results**

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.  
ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.  
Ppt; parts per trillion, or nanograms per liter (ng/L)  
Ppq; parts per quadrillion, or picograms per liter (pg/L)

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

**Regulated Contaminants**

<b>Disinfectants and Disinfection By-Products</b>	Collection Date	Highest Level	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Haloacetic Acids (HAA5)*</b>	2014	9	0-9.6	No goal for the total	60	ppb	N	By-product of drinking water disinfection
<b>Total Trihalomethanes (TTHM)</b>	2014	16	0-21.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely source of Contamination
<b>Barium</b>	2014	0.0079	0.0079-0.0079	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
<b>Cyanide</b>	2014	16.9	0-16.9	200	200	ppb	N	Discharge from plastic and Fertilizer factories; Discharge from steel/metal factories
<b>Fluoride</b>	2014	2.91	1.59-2.91	4	4.0	ppm	N	Erosion of natural deposits; Water additive promotes Strong teeth; Discharge from Fertilizer and aluminum factories
<b>Nitrate [measured as Nitrogen]</b>	2014	1.72	0.0125-1.72	10	10	ppm	Y	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of natural deposits
<b>Nitrite [measured as Nitrogen]</b>	2014	1	0-1.51	1	1	ppm	Y	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of natural Deposits
<b>Radioactive Contaminants</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely source of Contamination
<b>Gross alpha excluding radon and Uranium</b>	02/11/2009	3	0-3	0	15	pCi/L	N	Erosion of natural deposits

Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

<b>Synthetic organic Contaminants including Pesticides and herbicides</b>	<b>Collection Date</b>	<b>Highest Level Detected</b>	<b>Range of Levels Detected</b>	<b>MCLG</b>	<b>MCL</b>	<b>Units</b>	<b>Violation</b>	<b>Likely source of Contamination</b>
<b>Di (2-ethylhexyl) phthalate</b>	2014	1	0-0.5	0	6	ppb	N	Discharge from rubber and Chemical factories



Annual Drinking Water Quality Report  
TX1160039 NORTH HUNT SUD

Violations Table

Lead and Copper Rule			
The Lead and Copper Rule protects public health by minimizing lead and copper levels in drinking water, primarily by reducing water corrosivity. Lead and copper enter drinking water mainly from corrosion of lead and copper containing plumbing materials.			
Violation Type	Violation Begin	Violation End	Violation Explanation
LEAD CONSUMER NOTICE (LCR) 12/30/2013 02/03/2014			We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results.

Nitrite [measured as Nitrogen]			
Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.			

Violation Type	Violation Begin	Violation End	Violation Explanation
MCL, SINGLE SAMPLE	07/01/2014	09/30/2014	A water sample showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.

Public Notification Rule			
The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).			
Violation Type	Violation Begin	Violation End	Violation Explanation
PUBLIC NOTICE RULE LINKED TO VIOLATION	07/12/2011	2014	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.
PUBLIC NOTICE RULE LINKED TO VIOLATION	09/21/2011	2014	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.
PUBLIC NOTICE RULE LINKED TO VIOLATION	12/12/2011	2014	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.
PUBLIC NOTICE RULE LINKED TO VIOLATION	03/11/2012	2014	We failed to adequately notify you, our drinking water consumers, about a violation of the drinking water regulations.

**This page intentionally left blank**