



# *2000 Drinking Water Quality Report*

## **PLAINVIEW MUNICIPAL WATER SYSTEM**

Providing safe and reliable drinking water is the highest priority of the City of Plainview Water Department. City employees strive to produce and deliver water to your tap that meets or exceeds state and federal standards.

It is important to the City that you have information about your drinking water so you will have confidence in the product we deliver. You will find a list of what's in the water and at what levels. The information in this report is based on tests conducted in 2000.

**ON NOVEMBER 8th, 2000  
CITY OF PLAINVIEW  
WAS PRESENTED AN AWARD FOR  
OUTSTANDING OPERATIONS  
OF  
PUBLIC DRINKING WATER FACILITIES  
BY THE  
TEXAS NATURAL RESOURCE  
CONSERVATION COMMISSION**

## We welcome your comments

There are many opportunities available to learn more about the City of Plainview Water Production Department and water quality.

For questions or concerns about water quality, contact Darryel Pierce at (806) 296-1153. To request a speaker for your group, call (806) 296-1150.

For inquiries about public participation and policy decisions, contact the City Manager at (806) 296-1106.

The Water Department is part of the city government. The City Council meets the second and fourth Tuesday of each month. Call (806) 296-1100 for meeting times and location. You may make written comments to the City of Plainview at 901 Broadway, Plainview, Texas 79072.

Si tienes preguntas sobre la calidad del agua, puedes llamar a Felix Villarreal, Tecnico de Laboratorio, Ciudad de Plainview, (806) 296-1154.

Tambien puedes escribir a Felix Villarreal, 901 Broadway, Water Treatment Plan, Plainview, Texas 79072, con sus preguntas.

**Special Notice for the  
ELDERLY, INFANTS,  
CANCER PATIENTS, people  
with HIV/AIDS or other  
immune problems:**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Our Drinking Water  
Meets or Exceeds All Federal (EPA)  
Drinking Water Requirements**

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

**En Espanol**

Este report incluye la informacion importante sobre su aqua

beber. A obtener una copia de esta informacion o traducir en Espanol, llamar.

Our drinking water is **obtained** from Ground and Surface water sources. It comes from the OGALLALA AQUIFER and LAKE MEREDITH. TNRCC will be reviewing all of Texas= drinking water sources. The source water assessment process will be completed in three years.

**ALL drinking water may contain contaminants.**

Drinking water, **including bottled water**, may reasonably be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency=s (EPA) Safe Drinking Water Hotline (800) 426-4791.

**About The Attached Table**

The attached table contains all of the chemical constituents that have been found in your drinking water. U.S. EPA requires water systems to test for 97 constituents.

**Secondary Constituents**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not EPA. These constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

## **DEFINITIONS:**

### **Maximum Contaminant Level Goal (MCLG)**

- The level of a contaminant in drinking water below which there is not known or expected health risk. MCLGs allow for a margin of safety.

### **Maximum Contaminant Level (MCL)**

- The highest level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Treatment Technique - (TT)** A required process intended to reduce the level of a contaminant in drinking water.

**Action Level - (AL)** The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Turbidity** - a measure of the cloudiness of water. Turbidity is a good indicator of the effectiveness of water filtration system.

### **Nephelometric Turbidity Units (NTU)**

-The amount of Turbidity in a water sample.

**ppm** - Parts per million. One part per million equals one packet of artificial sweetener sprinkled into 250 gallons of iced tea.

**ppb** - Parts per billion. One part per billion is equal to one packet of artificial sweetener sprinkled into an Olympic-size swimming pool.

**pci/l** - Picocuries per liter is a measure of radioactivity in water. A Picocuries is 10<sup>-12</sup> curies and is the quantity of radioactive material producing 2.22 nuclear transformations per minute.

**Gross Beta Emitters** - The amount of radiation in a water sample.

**Plainview Municipal Waters Ground Surface Ogallala and Lake Meredith  
Inorganics**

Year	Constituent	Highest level at Any Sampling Point	Range of Detected Levels	MCL	MCLG	Units of Measure	Source of Constituent
1999	Arsenic	4.8	3.7000-4.8000	50	0	ppb	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
2000	Barium	0.175	0.0650-0.1750	2	2	ppm	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
1999	Fluoride	2.9	1.0000-2.9000	4	4	ppm	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories.
1999	Nitrate	4.65	0.1700-4.6500	10	10	ppm	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
1999	Selenium	9.1	2.0000-9.1000	50	50	ppb	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
1999	Gross alpha adjusted	5.1	5.1000-5.1000	15	0	pci/l	Erosion of natural deposits.
1999	Gross beta emitters	5.5	5.5000-5.5000	50	0	pci/l	Decay of natural and man made deposits.

**Organics**

Year	Constituent	Highest Ave. of any Sampling Point	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Constituent
2000-2000	Atrazine	0.11	0.0000-0.3200	3	3	ppb	Runoff from herbicide used on row crops
2000-2000	Xylenes	0.0011	0.0000-0.0011	10	10	ppm	Discharge from petroleum factories; Discharge from chemical factories
2000-2000	Dichloromethane	2.25	0.0000-4.5000	5	0	ppb	Discharge from pharmaceutical and chemical factories.
2000-2000	Dichloroethane 1,2	1	0.0000-1.0000	5	0	ppb	Discharge from industrial chemical factories.

**THM**

Year	Constituent	Average of all Sampling Points	Range of Detected Levels	MCL	MCLG	Unit of Measure	Source of Constituent
2000	Total Trihalomethanes	44.93	0.50-156.80	100	0	ppb	By-product of drinking water chlorination.

### Unregulated Contaminants

Year	Constituent	Average of all Sampling Points	Range of Detected Levels	Unit of Measure	Reason for Monitoring
2000-2000	Chloroform	5.94	0.0000-26.0000	ppb	Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2000-2000	Bromoform	5.43	0.0000-16.0000	ppb	Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2000-2000	Bromodi-chloromethane	9.18	0.0000-40.0000	ppb	Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2000-2000	Chlorodi-bromomethane	12.84	0.0000-49.0000	ppb	Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and where it needs to regulate those contaminants.

### Turbidity

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea and associated headaches.

Year	Constituent	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measures	Source of Constituent
1999	Turbidity	0.35	100.00	0.5	NTU	Soil runoff

### Lead and Copper

Year	Constituent	The 90 <sup>th</sup> percentile	Number of Sites exceeding Action Level	Action Level	Unit of Measures	Source of Constituent
1998	Copper	0.0990	0	1.3	ppm	Corrosion of household plumbing system; Erosion of natural deposits; Leaching from wood preservatives.
1998	Lead	2.2000	0	15	ppb	Corrosion of household plumbing systems; Erosion of natural deposits.

## COLIFORMS

What are coliforms?

Coliform bacteria are used as indicators of microbial contamination of drinking water because they are easily detected and found in the digestive tract of warm-blooded animals. While they are not disease producers, coliform is often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms; therefore their absence from water is a good indication the water is bacteriologically safe for human consumption.

Fecal coliform (mostly E-coli,) is a portion of the coliform bacteria group originating in the intestinal tract of warm-blooded animals that passes into the environment as feces. Fecal coliform is often used as an indicator of the fecal contamination of domestic water supply.

### **Total Coliform**

Year	Constituent	Highest Monthly Number of Positive Samples	MCL	Unit of Measure	Source of Constituent
1999	Total Coliform Bacteria	0	*	Presence	Naturally present in the environment

\* Two or more coliform found samples in any single month.

**Total Coliform            NOT DETECTED**

**Fecal Coliform            NOT DETECTED**

The City of Plainview collected over 300 total coliform bacteria samples in 2000.

FIRST CLASS  
PRESORT  
POSTAGE PAID  
PERMIT NO. 30  
PLAINVIEW, TEXAS