



PLAINVIEW, TX

explore the opportunities

2013 Annual Drinking Water Quality Report (Consumer Confidence Report)

PWS ID Number: **TX0950004**

PLAINVIEW MUNICIPAL WATER SYSTEM

Phone (806) 296-1153

Annual Water Quality Report for the period of January 1 to December 31, 2013

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

We Welcome Your Comments: There are many opportunities to learn more about the City of Plainview Water Production department and water quality. For questions or concerns about water quality, contact Felix Villarreal at (806) 296-1153. To request a speaker for your group, call (806) 296-1150. For inquiries about public participation and policy decisions, contact the City Manager at (806) 296-1106. The Water Department is part of the city government. The City Council meets the second and fourth Tuesday of each month. Call (806) 296-1107 for meeting times and location. You may make written comments to the City of Plainview at 901 Broadway, Plainview, Texas 79072.

For more information regarding this report contact: Name Felix Villarreal Phone (806) 296-1153

Este informe contiene información muy importante sobre el agua que usted bebe. Si tienes preguntas sobre la calidad del agua, puedes llamar a Felix Villarreal, Operario Principal, Ciudad de Plainview, (806) 296-1153. También puedes escribir a Felix Villarreal, 901 Broadway, Water Treatment Plant, Plainview, Texas 79072, con sus preguntas.

Special Notice – Required Language for all Community Public Water Systems: Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The source of drinking water used by PLAINVIEW MUNICIPAL WATER SYSTEM is Purchased Surface and Ground Water.

Information on Sources of Water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

The City of Plainview has a total of 16 wells. All of our wells draw water from the Ogallala Aquifer. All wells are active.

Information about Secondary Contaminants

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water sources(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWWW/>

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Felix Villarreal at (806) 296-1153.

Water Quality Test Results

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

na: not applicable.

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

Maximum Residual Disinfectant Level

Systems must complete and submit disinfection data on the Surface Water Monthly Operations Report (SWMOR). On the CCR Report, the system must provide disinfectant type, minimum, maximum and average levels.

Year	Disinfectant Type	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit	Source of Chemical
2013	Free CL2	.98	.40	1.74	4	4	ppm	Disinfectant used to control microbes.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	1 samples were positive		0	N	Naturally present in the environment.

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2013	1.3	1.3	0.0757	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2013	0	15	1.84	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2013	5	0 – 10.2	No goal for the total	60	ppb	N	By-product of drinking water chlorination.

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future

Total Trihalomethanes (TTHm)*	2013	6	0 – 14.7	No goal for the total	80	ppb	N	By-product of drinking water chlorination.
-------------------------------	------	---	----------	-----------------------	----	-----	---	--

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic **	2013	2	1.83 – 4.24	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Chromium	2013	3.39	1.92 – 3.39	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Thallium	2013	0.334	0 – 0.334	0.5	2	ppb	N	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories

** While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Barium	2013	0.0985	0.0921 – 0.0985	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	2013	2.6	0.96 – 2.62	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2013	3	0.88 – 2.66	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Nitrate Advisory - Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Selenium	2013	2.46	0 – 2.46	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
----------	------	------	----------	----	----	-----	---	---

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	2013	6.4	6.4 – 6.4	0	50	pCi/L	N	Decay of natural and man-made deposits.
Gross alpha excluding radon and uranium	2013	7.7	7.7 – 7.7	0	15	pCi/L	N	Erosion of natural deposits.
Combined Radium 226/228	2013	1.2	1.2 – 1.2	0	5	pCi/L	N	Erosion of natural deposits.

Regulated Contaminants

Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Carbon Tetrachloride	2013	1	0 – .058	0	5	ppb	N	Discharge from chemical plants and other industrial activities.
Tetrachloroethylene	2013	1	0 – 0.55	0	5	ppb	N	Discharge from factories and dry cleaners.

Turbidity

	Limit (Treatment Technique)	Level Detected	Violation	Likely Source of Contamination
Highest single measurement	1 NTU	0.8	N	Soil runoff.
Lowest monthly % meeting limit	0.3 NTU	99.45%	N	Soil runoff.

Violations Table

Note on Violations:

TCEQ recently completed a review of Public Notice violations that were historically present in our database. This review was done at the request of the Environmental Protection Agency and was triggered by the TCEQ migration to the Safe Drinking Water Information System (SDWIS). Following EPA guidelines TCEQ returned to compliance many PN violations that had existed, but may have not been reported on a prior year CCR. We strongly encourage you to check Drinking Water Watch (<http://dww.tceq.texas.gov/DWWW/>) for the current status of any violations displayed on this page.

The City of Plainview had no violations for the year 2013.

Drought Contingency Plan and Water Loss Audit

The City maintains a drought contingency plan to preserve the water supply in case of emergency conditions. The plan can be easily implemented if emergency or drought conditions persist for any length of time. The drought contingency plan ensures that ample water will always be available to meet the most critical needs of residents and business. The City of Plainview urges everyone to be water wise. During the summer, 50% - 80% of a household's water consumption is outdoors. By all working together, we can each do our part to help conserve this most precious commodity! For more information on being a smart water consumer, for a free brochure on the subject, feel free to contact the City of Plainview Water Production Department at 806-296-1153.

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan – Dec 2013, our system lost an estimated 296,441,000 gallons of water. If you have any questions about the water loss audit please call 806-296-1153.